

Nordic E trade AB
Fraktflygargatan 18
128 30 SKARPNÄCK

Classification of reaction to fire in accordance with EN 13501-1

1 Introduction

This classification report defines the classification assigned to “Peel & Stick Matt” in accordance with the procedure given in EN 13501-1:2018.

2 Details of classified product

2.1 General

The product “Peel & Stick Matt” is defined as a decorative wallcoverings. Its classification is valid for the following end use application: wallcoverings.

According to the owner of this classification report, this product complies with the European product specification EN 15102:2007+A1:2011.

The sample was delivered by the client. RISE, Fire and Safety was not involved in the sampling procedure.

2.2 Product description

The product, Peel & Stick Matt, is fully described below or is fully described in the test reports provided in support of classification listed in Clause 3.1.

According to the client:

Wall covering product called “Peel & Stick Matt”. Consisting of 130 g/m² non-woven and Removable Clear Acrylic Tack. The non-woven material consists of 89 percent cellulose and 11 percent polyester. The acrylic adhesive has a nominal thickness of 36 µm.

3 Reports and results in support of this classification

3.1 Test reports

Table 1 Test report forming the basis for this classification.

Name of laboratory	Name of sponsor	Test report reference no	Accredited test methods and date
RISE	Nordic E Trade AB	O100741-1314454-1	EN 13823:2020+A1:2022 and EN ISO 11925-2:2020

RISE Research Institutes of Sweden AB

Postal address
Box 857
501 15 BORÅS
SWEDENOffice location
Brinellgatan 4
504 62 Borås
SWEDENPhone / Fax / E-mail
+46 10-516 50 00
+46 33-13 55 02
info@ri.seConfidentiality level
C3 - Sensitive

This report may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.

3.2 Test results

The test results listed below show the worst case as found in the test programme performed and reported according to the table above. The tests have been carried out on products covering the colour range.

Table 2 Test results showing the worst case as found in the test program performed.

Test method	Parameter	Number of tests	Results	
			Continuous parameter mean (m)	Compliance with parameters
EN ISO 11925-2		12		
Edge/Surface flame attack**				
30 s exposure	$F_s \leq 150$ mm	(-)		Compliant
Flaming droplets/particles	Ignition of filter paper	(-)		No ignition of filter paper
EN 13823		5		
	$FIGRA_{0,2MJ}$ (W/s)	245		Compliant
	$FIGRA_{0,4MJ}$ (W/s)	129		Compliant
	$LFS < \text{edge}$	(-)		Compliant
	THR_{600s} , (MJ)	1.5		Compliant
	$SMOGRA$, (m^2/s^2)	0		Compliant
	TSP_{600s} , (m^2)	21		Compliant
	Flaming droplets/particles	(-)		No flaming droplets/particles

** : as required to the end use application of the product

(-) : not applicable

4 Classification and field of application

4.1 Reference of classification

This classification has been carried out in accordance with clause 11 and 15 of EN 13501-1:2018.

4.2 Classification

The product called “Peel & Stick Matt” in relation to its reaction to fire behaviour is classified:

C

The additional classification in relation to smoke production is:

s1

The additional classification in relation to flaming particles/droplets is:

d0

The format of the reaction to fire classification for construction products excluding floorings and linear pipe thermal insulation product is:

Fire Behaviour		Smoke Production			Flaming Droplets	
C	-	s	1	,	d	0

i.e. A1 to F (as applicable) – s1, 2 or 3 (as applicable), d0, 1 or 2 (as applicable)

Reaction to fire classification: *C-s1,d0*

4.3 Field of application:

This classification is valid for the following product parameters:

Product description, as specified in 2.2 in this report

Nominal non-woven area weight: 130 g/m².

Nominal acrylic tack glue thickness: 36 µm.

Colour range: All colours

This classification is valid for the following end use conditions:

Substrates

- Gypsum plasterboard (paper faced) and any end use substrate of Euroclass A1 or A2-s1,d0 at least 12 mm thick. Having a density $\geq 525 \text{ kg/m}^3$.

Fixings

- Self-adhesive contained in the product.

Joints


- Vertical joints.

5 Limitations

This classification document does not represent type approval or certification of the product.


RISE Research Institutes of Sweden AB Fire and safety - Reaction to Fire Medium Scale Lab

Performed by



Haniyah Ashtiani

Examined by



Richard Johansson

Verifikat

Transaktion 09222115557551407471

Dokument

O100741-1314454-2 Nordic E Trade Photowall 13501-1
Huvuddokument
4 sidor
Startades 2025-07-07 09:31:24 CEST (+0200) av Richard
Johansson (RJ)
Färdigställt 2025-07-07 10:35:39 CEST (+0200)

Signerare

Richard Johansson (RJ)
RISE Research Institutes of Sweden AB
Org. nr 556464-6874
richard.johansson@ri.se
+46 10 516 56 75

Richard Johansson

Signerade 2025-07-07 09:36:08 CEST (+0200)

Haniyah Ashtiani (HA)
RISE AB
haniyah.ashtiani@ri.se

Haniyah Ashtiani

Signerade 2025-07-07 10:35:39 CEST (+0200)

Detta verifikat är utfärdat av Scrive. Se de dolda bilagorna för mer information/bevis om detta dokument. Använd en PDF-läsare som t ex Adobe Reader som kan visa dolda bilagor för att se bilagorna. Observera att om dokumentet skrivs ut kan inte integriteten i papperskopian bevisas enligt nedan och att en vanlig papperutskrift saknar innehållet i de dolda bilagorna. Den digitala signaturen (elektroniska förseglingen) säkerställer att integriteten av detta dokument, inklusive de dolda bilagorna, kan bevisas matematiskt och oberoende av Scrive. För er bekvämlighet tillhandahåller Scrive även en tjänst för att kontrollera dokumentets integritet automatiskt på: <https://scrive.com/verify>

